

FIRE SAFETY CERTIFICATE

R.C.NO : 1008 /V/2025
NOC.NO : 80 /2025

Fire And Rescue Station, karur,
Date: 01-11-2025

Certified that THE INDIAN PUBLIC SCHOOL (name of the building or premises) at SF.NO : 371 PART , PUNNAM VILLAGE ,ARAVAKURICHI (TK), KARUR- 639006 (Address) Comprised of Ground floor, First Floor Second floor owned / Occupied by THE INDIAN PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire service Rules, and verified by the officers concerned of Fire Service on 31/10/2025 in the presence of THE PRINCIPAL, SF.NO : 371 PART , PUNNAM VILLAGE ,PUGALUR (TK), KARUR- 639006 and that the building / premises is fit for occupancy up to classes I to XII (X/ XII) with effect from 01.11.2025 up to 31.08.2028 in accordance with rule and subject to compliance of specific conditions as appended :-

CONDITIONS:

1. The swimming pool in the school premises should be operated after obtaining permission from the appropriate government department and should not be used until then.
2. Any Construction works and renovation works should be permitted all licence Authorities
3. All Fire Fighting Equipments Should be Neat and Clean Periodically .
4. Hose Reel Hose Should be Installed the Building (3 x 2 x 15mts).
5. This certificate should be used only educational purpose.
6. Every six months should be conducted fire mock drill and evacuations drill.
7. This Certificate is valid up to 31.08.2028



Signature with seal

C.THIRUMURUGAN
Assistant District Officer,
Tamilnadu Fire and Rescue Station,
Karur, Karur (Dt) - 639001.

Name : **Thiru C.THIRUMURUGAN**
Designation : **ASSISTANT DISTRICT OFFICER**

Name and Address of the Department /Office :

To :

**THE PRINCIPAL,
THE INDIAN PUBLIC SCHOOL
SF.NO : 371 PART ,
PUNNAM VILLAGE ,
ARAVAKURICHI (TK), KARUR- 639006**

Copy to :

- 1).Certificate issuing officer
- 2).District Officer,Karur District